Wastewater System Alternative Design Concepts Evaluation Matrix Phase 3_____

Criteria	Criteria Indicator	Alternative 1	Alternative 2	Alternative 3	Alternative 4	Consultant
		Membrane Bioreactor	Sequencing Batch Reactor	Aerobic Foam Media	Moving Bed Biofilm Reactor	
			(SBR)	Trickling Filter	(MBBR)	
SOCIO-CUI TURAL EL					(IIIDDI()	
SOCIO-COLI ORAL LI	Bormapont or long term paise	Noise associated with the	Noise associated with the	Limited mechanical equipment	Noise associated with the operation of	lada /
Operational Nuisance Impacts (noise, odours)	 Permanent of folg-term hoise impacts during operation of wastewater treatment plant or other wastewater system facilities. Operational odours from treatment technology. 	operation of the membrane bioreactor system can be mitigated to ensure applicable noise guidelines are met at the proposed and existing noise sensitive receptors. Odours mitigated through the use of enclosed tanks and carbon filters on vents.	operation of the SBR system can be mitigated to ensure applicable noise guidelines are met at the proposed and existing noise sensitive receptors. Odours mitigated through the use of enclosed tanks and carbon filters on vents.	with this technology, no air blowers or large equipment, so minimal noise generation. Odours mitigated through the use of enclosed tanks and carbon filters on vents.	the MBBR system can be mitigated to ensure applicable noise guidelines are met at the proposed and existing noise sensitive receptors. Odours mitigated through the use of enclosed tanks and carbon filters on vents.	Burnside
		Less Preferred	Less Preferred	More preferred	Less Preferred	
Operational Traffic Impacts	Localized traffic impacts based on frequency of operation and maintenance activities.	Process requires periodic removal of primary solids and aerobic sludge by licensed hauling trucks. Estimated frequency twice per year.	Process requires periodic removal of primary solids and aerobic sludge by licensed hauling trucks. Estimated frequency twice per year.	Process requires periodic removal of primary solids only; no aerobic sludge generated by this process. Estimated frequency once per year.	Process requires periodic removal of primary solids and aerobic sludge by licensed hauling trucks. Estimated frequency twice per year.	Burnside
		Less Preferred	Less Preferred	Most Preferred	Less Preferred	
SUMMARY OF SOCIO-C	CULTURAL ENVIRONMENT	4/10 Less Preferred	4/10 Less Preferred	9/10 Most Preferred	4/10 Less Preferred	
TECHNICAL ENVIRO	NMENT					
Ability to meet water treatment / storage criteria		Best available technology for phosphorus removal. Can meet objectives for other parameters (BOD, TSS, pathogens) Somewhat inconsistent nitrate removal performance; may require supplemental equipment/ processes.	Can meet effluent objectives for most parameters (BOD, TSS, pathogens and phosphorus). May not be able to provide nitrate removal to desired levels; may require supplemental equipment/ processes.	Can meet all effluent objectives.	Can meet effluent objectives for most parameters (BOD, TSS, pathogens and phosphorus). Somewhat inconsistent nitrate removal performance; may require supplemental equipment/ processes to meet objectives.	Burnside
		Somewhat preferred	Less preferred	Most preferred	Less preferred	
Land area requirements	 Footprint of above ground equipment. Footprint of below ground equipment including piping. 	Above ground building to house UV disinfection equipment, chemical dosing, controls, membranes and associated pumps, air blowers. Below ground concrete tanks to contain pre-treatment, aerobic and anoxic process. Most compact overall footprint, but largest above ground building footprint.	Above ground building to house UV disinfection equipment, chemical dosing, controls, air blowers, tertiary filters. Below ground concrete tanks to contain SBR aerobic and anoxic processes. Similar to Alternative 4.	Above ground building to house UV disinfection equipment, chemical dosing, controls, tertiary filters. Below ground tanks (650 to 700 m2) would contain the majority of treatment equipment and processes. Could be entirely housed in above ground containers. Similar overall footprint to Alternatives 2 and 4. Smallest building footprint.	Above ground Control Building to house UV disinfection equipment, chemical dosing, controls, air blowers, tertiary filters. Below ground tanks to contain the majority of treatment equipment and processes including bioreactors, clarifiers, anoxic tanks. Similar to Alternative 2.	Burnside
		Less Preferred	Somewhat Preferred	More Preferred	Somewhat Preferred	
Modularity	Degree of flexibility of system size and phasing.	System can be modular. Number of treatment "trains" will be variable depending on specific membrane supplier and associated capacities. Suspended growth process is not resilient to low flows and loadings during initial phase as	System is somewhat modular. Can be constructed as multiple parallel treatment trains, but may require more initial capital outlay than other options. Suspended growth process is not resilient to low flows and loadings during initial phase as dwellings	High degree of flexibility to accommodate multiple treatment trains and modular installation. Fixed film process is resilient to low flows and loadings during initial phase as dwellings gradually become occupied.	System is somewhat modular. Can be constructed as multiple parallel treatment trains. Process contains both suspended growth and fixed film, but only somewhat resilient to low flows and loadings during initial phase as dwellings gradually become occupied	Burnside

Wastewater System Alternative Design Concepts Evaluation Matrix Phase 3_____

Criteria	Criteria Criteria Indicator		Alternative 2 Sequencing Batch Reactor (SBR)	Alternative 3 Aerobic Foam Media Trickling Filter	Alternative 4 Moving Bed Biofilm Reactor (MBBR)	Consultant
		dwellings gradually become occupied. Plant may struggle to meet effluent objectives during initial phases of development due to low incoming sewage volumes	gradually become occupied. Plant may struggle to meet effluent objectives during initial phases of development due to low incoming sewage volumes.		Plant may struggle to consistently meet effluent objectives during initial phases of development due to low incoming sewage volumes.	
		Less Preferred	Least Preferred	Most preferred	Somewhat preferred	
Operation and Maintenance requirements and complexity	 Frequency of maintenance. Maintenance resources required (e.g., staffing, training / certifications, etc.). Regulatory testing and sampling. 	Operator on site 3x per week for system checks Highest level of mechanical parts and complex equipment. Requires air blowers, Chemical addition required for removal of phosphorus and nitrogen. Regular membrane cleaning and replacement required.	Operator on site 3x per week for system checks Moderate level of mechanical parts and complex equipment. Requires air blowers. Chemical addition required for removal of phosphorus and nitrogen.	Operator on site 1x per week for system checks Minimal mechanical parts and no complex equipment. No air blowers required. Chemical addition required for removal of phosphorus and nitrogen.	Operator on site 1x per week for system checks Moderate level of mechanical parts and complex equipment. Requires air blowers. Chemical addition required for removal of phosphorus and nitrogen.	Burnside
		Least Preferred	Less Preferred	Most Preferred	Somewhat Preferred	
SUMMARY OF TECHNI EVALUATION	CAL ENVIRONMENT	8/20 Less Preferred	8/20 Less Preferred	19/20 Most Preferred	11/20 Somewhat Preferred	
FINANCIAL ENVIRON	IMENT					
Comparative capital	Estimate of capital costs.	\$3.4 million	\$3.1 million	\$2.5 million	\$2.8 million	Burnside
costs		Least Preferred	Less Preferred	Most Preferred	Somewhat Preferred	
Estimated operations	Estimate of operational costs per	\$160,000 to \$180,000	\$160,000 to \$180,000	\$60,000 to \$80,000	\$80,000 to \$100,000	Burnside
and maintenance costs	year.	Less Preferred	Less Preferred	Most Preferred	Somewhat Preferred	
Estimated life cycle	Estimate of life cycle cost	\$6.2 million	\$5.9 million	\$3.6 million	\$4.2 million	Burnside
costs		Least Preferred	Less Preferred	Most Preferred	Somewhat Preferred	
SUMMARY OF FINANC	IAL ENVIRONMENT	2/10 Least Preferred	2/10 Least Preferred	10/10 Most Preferred	6/10 Somewhat Preferred	
OVERALL EVALUATIO	N	5/15 Less Preferred	5/15 Less Preferred	15/15 Most Preferred	8/15 Somewhat Preferred	
RECOMMENDATION		Not Carried Forward	Not Carried Forward	Carried Forward	Not Carried Forward	

Ranking Order of Preference

Least Preferred

Less Preferred

Somewhat Preferred

More Preferred

Most Preferred

Water System Alternative Design Concepts Evaluation Matrix Phase 3

Criteria	Criteria Indicator	Alternative 1A Primary Disinfection- Ultraviolet Disinfection	Alternative 1B Primary Disinfection - Chlorine	Alternative 2A Aesthetic (Hardness) - Ion Exchange	Alternative 2B Aesthetics (Hardness) - Softening Membranes	Alternative 2C Aesthetics (Hardness) - Crystallization Technology	Alternati Storage – Grour
NATURAL EN	VIRONMENT						
Impacts to	General impacts to the natural environment	None.	• Negative impact on natural environmental in the event of a spill.	Potential impact to soils as result of spray irrigation to golf course.	Minimal to no impact.	Minimal to no impact.	Minimal to
Environment		Most preferred	Least preferred	Least preferred	Most preferred	Most preferred	Most preferre
SUMMARY OF	NATURAL	3/3 Most Preferred	1/3 Least Preferred	1/3 Least Preferred	3/3 Most Preferred	3/3 Most Preferred	3/3 Most Pi
SOCIO-CULT	URAL ENVIRO	NMENT					
Operational Nuisance Impacts (noise, odours)	 Permanent or long-term noise impacts during operation of wastewater treatment plant or other wastewater system facilities. Operational odours from treatment 	 Minimal noise. No odours from treatment. Minimal operational nuisance. 	 Minimal noise related to pump operation. Minimal chlorine odour. Ventilation system required to ensure cycling of air for chemical room. Moderate operational nuisance. 	 Minimal noise related to pump operation. Moderate noise for short duration during operation/cleaning. Higher operational nuisance. 	 Minimal noise related to pump operation. Higher operational nuisance. 	 Minimal noise and operational nuisance. Maintenance for each residential unit within the development would be required. 	 Minimal noi No odour. Minimal open nuisance.
	technology.	Most preferred	More preferred	More preferred	More preferred	Least preferred	Most preferre
Operational Traffic Impacts	Localized traffic impacts based on frequency of operation and maintenance	Minimal traffic impact due to regular inspection and maintenance.	Minimal traffic impact due to re-supply of chemicals (3 to 4 weeks) and regular inspection and maintenance.	• Minimal traffic impact due to salt deliveries (3 to 4 weeks) and regular inspection and maintenance.	Minimal traffic impact due to regular inspection and maintenance.	Minimal to no traffic.	Minimal trai due to regu inspection a maintenance
	activities	More preferred	More preferred	More preferred	More preferred	Most preferred	More preferre
Visual impacts	Visual impacts to adjacent residences	 None as the equipment will be located inside a building. 	None as the equipment will be located inside a building.	None as the equipment will be located inside a building.	 None as the equipment will be located inside a building. 	None as the equipment will be located inside a building.	 Can be obs grade. Less archite options con Alternative Susceptible vandalism.
		Most preferred	Most preferred	Most preferred	Most preferred	Most preferred	More Preferre
SUMMARY OF CULTURAL EN EVALUATION	SOCIO- NVIRONMENT	8/9 Most Preferred	7/9 More Preferred	7/9 More Preferred	7/9 More Preferred	7/9 More Preferred	7/9 More Pr

tive 3A - Above und	Alternative 3B Storage – Below Ground	Consultant
o no impact.	Minimal to no impact.	Others
red	Most preferred	
Preferred	3/3 Most Preferred	
oise. perational	 Minimal noise. No odour. Moderate operational nuisance (difficult to service and inspect). 	Jade
red	More preferred	
affic impact jular and nce.	 Minimal traffic impact due to regular inspection and maintenance. 	TYLin
red	More preferred	
oserved at itectural ompared to e 3b. le to l. red	Cannot be observed at grade. Most preferred	TYLin
Preferred	7/9 More Preferred	

Water System Alternative Design Concepts Evaluation Matrix Phase 3

Criteria	Criteria Indicator	Alternative 1A Primary Disinfection- Ultraviolet Disinfection	Alternative 1B Primary Disinfection - Chlorine	Alternative 2A Aesthetic (Hardness) - Ion Exchange	Alternative 2B Aesthetics (Hardness) - Softening Membranes	Alternative 2C Aesthetics (Hardness) - Crystallization Technology	Alternati Storage – Grou
	NT						
Ability to meet water treatment / storage criteria	 Can this technology meet the water treatment / storage criteria? Formation of by-products or impact to the water quality. Impact to water taste/odour. Production of wastewater. 	 Can be met. Minimal formation of disinfection by- products. Does not change the taste and odour of water. No chlorine residual in treated water and as such offers no protection against re-infection during distribution. Effective against Cryptosporidium and Giardia. Effective as part of a multi-barrier approach to provide a second form of treatment. 	 Can be met. Formation of disinfection by- products. Distinctive odour and taste in treated water. Chlorine residual remains in the storage and distribution stages to allow for maintenance of water quality. Negative impact to ion exchange (Alternative 2a) and softening membranes (Alternative 2b) efficiency. Not effective against Cryptosporidium. Effective as part of a multi-barrier approach to provide a second form of treatment. 	 Can be met. Similar level of hardness removal efficiency as Alternative 2b. Regular resin regeneration may result in potential salt buildup in golf course lands. Wastewater production (5 to 8% of feed water) during the regeneration process. This system will produce less wastewater than Alternative 2b. 	 Can be met Similar level of hardness removal as Alternative 2a. Membranes don't tolerate exposure to chlorine, and repeated chlorine exposure can lead to lower efficiency. Does not generate salt. Increased amount of wastewater (10% of feed water). This system will produce more wastewater than Alternative 2a. 	 Can be met on small scale, but further investigation into commercial scale is required. Residents may switch to salt softeners, resulting in potential salt build up in golf course lands. Lower efficiency than Alternative 2a and 2b. Not suitable for well water with Iron. Does not remove minerals (calcium and magnesium ions) from water but converts them from one state to the other (precipitate). Difficult to test for effectiveness as it does not remove calcium and magnesium ions. Does not use salt or other chemical conditioning agents. Treated water would still result in some soft scale formation on external surfaces. Does not produce wastewater. There is no backwashing or salt discharge. 	Can be me
		Most preferred	More preferred	More preferred	Most preferred	Least preferred	More preferr
Land area requirements	 Footprint of above ground equipment. Footprint of below ground equipment 	Similar to Alternative 1b.	 Similar to Alternative 1a. 	Similar to Alternative 2b.	• Similar to Alternative 2a.	 No spatial requirements within water treatment plant, only in residential units. 	Larger built footprint as two separa structures.
	including piping.	More preferred	More preferred	More preferred	More preferred	Most preferred	More preferre

ive 3A Above nd	Alternative 3B Storage – Below Ground	Consultant
t. ed	• Can be met.	TYLin
ding a result of te	Minimal increase in footprint. Reservoir can be integrated into the below ground foundation design of the WTP. Most preferred	TYLin
u l	most prototted	

Water System Alternative Design Concepts Evaluation Matrix Phase 3

Criteria	Criteria Indicator	Alternative 1A Primary Disinfection- Ultraviolet Disinfection	Alternative 1B Primary Disinfection - Chlorine	Alternative 2A Aesthetic (Hardness) - Ion Exchange	Alternative 2B Aesthetics (Hardness) - Softening Membranes	Alternative 2C Aesthetics (Hardness) - Crystallization Technology	Alternati Storage – Grou
Modularity	 Degree of flexibility of system size and phasing. 	 Additional equipment can be phased with minimal upgrades requirements. 	 Flexible as an additional pump or chemical storage tank can be installed if required. 	 Additional equipment can be phased with minimal upgrades requirements. 	 Additional equipment can be phased with minimal upgrades requirements. 	• N/A	 Can be exp vertically, if Second tar provided fo capacity wi foundation required.
		More preferred	More preferred	More preferred	More preferred		Most preferre
Operation and Maintenance requirements and complexity	 Frequency of maintenance. Maintenance resources required (e.g., staffing, training / certifications, etc.). Regulatory testing and sampling. 	 Quartz sleeves and Teflon tubes needs to be cleaned regularly by mechanical wipers, ultrasonics, or chemicals. Inspection of UV chamber interior required every six months. Safe for operators as there is no chemical handling, transportation, or storage. Requires less contact time than Alternative 1b. 	 Cleaning and maintenance of the system components is required every six months. Equipment and chlorine storage tank to be inspected and cleaned annually. Chemical delivery every 3 to 4 weeks. Regular inspection of the equipment, chlorine solution and free chlorine residual levels, adjustment of equipment and dosage rates as required. All forms of chlorine are highly corrosive and toxic as such, storage, shipping, and handling pose a risk to operators and require increased training and safety procedures than Alternative 1a. 	 Ion exchange resin needs to be replaced every 8-12 years. Chemical delivery (dry salt) required every 3 to 4 weeks. Regular regeneration of resin is required. Periodic inspection and maintenance of brine tank. 	 Membranes replacement (approx. every 10 years). Regular cleaning of membranes is required. Periodic inspection and maintenance. 	 Media or cartridge replacement range is from 1 to 3 years. No drainage required. Pre-filter to be replaced every 3 to 6 months. Periodic inspection and maintenance Residents would be responsible for operation. 	 Minimal ins and mainter requirement Manways preasy access Defects/lear easily identified repaired. More prone during the state of the s
		Most preferred	More preferred	More preferred	Most preferred	Least preferred	Most preferre
		10/12 Most Proferred	8/12 More Preferred	8/12 More Preferred	10/12 Most Proferred	5/9 Least Preferred	10/12 Most
FINANCIAL E	NVIRONMENT	Teleffed			TETETTEU		

ve 3A Above nd	Alternative 3B Storage – Below Ground	Consultant
oanded required. Ik can be r additional th similar design, if	 Additional water reservoir cells can be constructed. Complexity to expand a subgrade reservoir is higher than expanding an above ground tank due to excavation, existing foundation constraints, and shoring. 	TYLin
pection nance its. provided for is. iks are iffied and e to freezing winter.	 Minimal inspection and maintenance requirements. Increased confined space training and safety procedures. Difficult identifying and repairing cracks and leaks. Natural protection against the extreme cold and heat, easier to maintain temperate. 	TYLin
ed	More preferred	
Preferred	9/12 More Preferred	

Fergus Golf Club Redevelopment EA

Water System Alternative Design Concepts Evaluation Matrix Phase 3

Criteria	Criteria Indicator	Alternative 1A Primary Disinfection- Ultraviolet Disinfection	Alternative 1B Primary Disinfection - Chlorine	Alternative 2A Aesthetic (Hardness) - Ion Exchange	Alternative 2B Aesthetics (Hardness) - Softening Membranes	Alternative 2C Aesthetics (Hardness) - Crystallization Technology	Alternative 3A Storage – Above Ground	Alternative 3B Storage – Below Ground	Consultant
Comparative capital costs	Estimate of capital costs.	• Higher	• High	• Similar to Alternative 2b.	• Similar to Alternative 2a.	Higher capital costs to install all residential units when compared to a single system at the water treatment plant.	 Moderate Less excavation and shoring systems Dependent on soils and groundwater Insulation and mixing required 	 High Deeper and larger excavation and shoring systems Dependent on soils and groundwater Insulation and waterproofing required 	TYLin
Estimated operations and maintenance costs	Estimate of operational costs.	 More preferred High Ballasts and quartz sleeves to be replaced every 5 years. Lamps to be replaced annually. High energy consumption. 	Most preferred • Higher • Costs required for training and emergency preparedness. • Moderate energy consumption. • Re-supply of chemicals (3-4 weeks). • Increased ventilation requirements.	 Most preferred High Regular regeneration and maintenance of resin. Re-supply of dry salt. Moderate energy consumption. 	 Most preferred High Cleaning of membranes. Membrane replacement (every 10 years). High energy consumption. 	 More preferred High due to number of units Media or cartridge to be replaced every 1 to 3 years. No drainage. Low energy consumption. 	 Most preferred Low Similar pumping costs. Can be visually inspected. Moderate cost of repairs as tank is above grade. 	 More preferred Low Similar pumping costs. Higher cost of repairs due to confined space and potential excavation. Higher costs of training and emergency preparedness. 	TYLin
	Estimate of	Most preferred	More preferred	More preferred	More preferred	More preferred	Most preferred	Most preferred	
Estimated life cvcle costs	life cycle cost	Mana professod	Mara professed	Mara Droforrad	Mana proformed	number of units	Mara professed	Mara professed	TYLin
SUMMARY OF	FINANCIAL								
ENVIRONMEN	T EVALUATION	//9 Most Preterred	//9 More Preterred	//9 Most Preferred	//9 Most Preterred	6/9 More Preterred	8/9 Most Preferred	//9 More Preterred	
OVERALL EVA		12/12 Most Preferred	7/12 More Preferred	8/12 More Preferred	11/12 Most Preferred	8/12 More Preferred	11/12 Most Preferred	9/12 More Preferred	
RECOMMEND	ATION	Recommended			Recommended		Recommended		

Evaluation Order of Preference

Least Preferred

More Preferred

Most Preferred

Assumptions List:

1. UV Disinfection will be provided for Primary Disinfection followed by Chlorine disinfection for Secondary. This provides a multi-barrier approach for disinfection. Since chlorination will be used this is the more preferred method to provide the multi-barrier approach.

Water System Alternative Design Concepts Evaluation Matrix

Phase 3

- 2. UV disinfection is required due to the downstream softening membranes. Chlorination for primary disinfection would have negative impacts on the membranes.
- 3. Softening membranes will provide the most effective solution for removing water hardness without using water softeners that are typically salt based solutions. The alternatives are problematic when tying into the irrigation design for potential of salt accumulation within the irrigation ponds potentially killing the grass long term.
- 4. Evaluation for above ground storage will only proceed to evaluate a standpipe. Elevated Tank is ruled out due to economic factors
- 5. System design will meet 4log requirements for virus removal.