




PROPOSED TREATMENT SYSTEM RATED FOR 160,000 L/day

PROPOSED SHALLOW BURIED TRENCH LEACHING BED RATED FOR 160,000 L/day C/W 17 CELLS EACH WITH 126m OF DISTRIBUTION PIPE FOR A TOTAL DISTRIBUTION PIPE LENGTH OF 2,142m



KEY PLAN  
SCALE: N.T.S.

**LEGEND**


- - - PROPERTY BOUNDARY
- PROPOSED LEACHING BED
- PROPOSED TREATMENT TANK AREA
- - - PROPOSED COLLECTION SYSTEM PIPING
- EXISTING WELL
- ALL EXISTING AND FUTURE SITES SERVICED BY ONE CENTRALIZED SEWAGE SYSTEM



Client **PONDEROSA NATURE RESORT 1218 CONCESSION RD 8 W, FRELTON, ONTARIO**

Figure Title **PONDEROSA NATURE RESORT WASTEWATER SYSTEM IMPROVEMENTS SCHEDULE C CLASS EA**

ALTERNATIVE SOLUTION 3 - SUBSURFACE DISCHARGE



Drawn MC	Checked AE	Date 4/18/2024	Figure No.
Scale 1:2,500	Project No. 300050185.0000		<b>FIG 7.6</b>